

SPECIFICATION

addaset
resin bound aggregate surfacing

addagrip

Urban Pathways

Typical base build up for occasional maintenance vehicles



0.5mm dia grit cast onto uncured surface



Surface Course

hand applied and trowelled to a smooth finish by Addagrip approved installers



The typical depth of Addaset resin bound paving surface
3mm aggregate formulation requires a minimum of 16mm
6mm aggregate formulation requires a minimum of 18mm
10mm aggregate formulation requires a minimum of 24mm

Binder Course

laid by others in well compacted layers to a minimum fall of 1.5%



A 50mm depth of AC 14 open surf asphalt concrete max 160 / 220 pen to BS EN 13108 - 1:2006

Sub-base

laid by others in well compacted layers to a minimum fall of 1.5%



A 150 minimum depth of well compacted non-frost susceptible type 1 granular sub base to SHW clause 803 or locally available secondary or recycled aggregates which comply with the requirements of the specification for Highways Works for sub-bases.

Capping Layer - (if required)



Sub-grade



NOTE: A suitable steel, wood, brick, stone or aluminium edging should be provided to ensure a neat edge detail.

Any advice, recommendation or information given by Addagrip Surface Treatments UK Limited is based on practical experience and is believed to be accurate at the time of publication, no liability or responsibility of any kind (including liability for negligence) is accepted in this respect by the company, its Servants, or Agents.

The figures quoted do not constitute a specification. They represent typical values obtained for this product.